

APPENDIX E

NOISE STUDY

CRANE ENERGY STORAGE
SANDHILL ENERGY STORAGE

SOUND STUDY

CRANE AND SANDHILL ENERGY STORAGE
PROJECT NO. 176103

REVISION 0
DECEMBER 2024

CONTENTS

EXECUTIVE SUMMARY I

1.0 Acoustic Terminology 1-1

2.0 Applicable Regulations 2-1

2.1 State of Minnesota 2-1

2.2 Olmsted County, Minnesota 2-1

2.3 Kalmar Township, Minnesota 2-1

3.0 Predictive Modeling 3-1

3.1 Methodology 3-1

3.2 Project Sound Sources 3-1

3.3 Model Results 3-2

4.0 Conclusion 4-1

APPENDIX A – FIGURES

APPENDIX B – MODELED SOUND LEVELS

TABLES

Table 1-1: Typical Sound Pressure Levels Associated with Common Sound Sources 1-2

Table 2-1: MPCA Sound Level Limitations 2-1

Table 3-1: Sound Modeling Parameters 3-1

Table 3-2: Modeled Source Sound Level Assumptions 3-2

Table 3-3: Modeled Sound Level Results 3-2

Table 3-4: Proximity of Residences within 3,200 feet 3-3

List of Abbreviations

Abbreviation	Term/Phrase/Name
BESS	battery energy storage system
CadnaA	Computer Aided Noise Abatement
dB	decibels
HVAC	heating ventilation and air conditioning
Hz	Hertz
ISO	International Organization of Standardization
L _{eq}	equivalent-continuous sound level
L ₁₀	sound level not to be exceeded 10% of the time
L ₅₀	sound level not to be exceeded 50% of the time
MPCA	Minnesota Pollution Control Agency
NAC	Noise Area Classification
Project or Projects	Crane Energy Storage and Sandhill Energy Storage
PWL	sound power level
SPL	sound pressure level

Executive Summary

Burns & McDonnell conducted a sound assessment study for two (2) adjacently located energy storage projects, the proposed Crane Energy Storage and Sandhill Energy Storage projects (“Project” or “Projects”). The Projects are comprised of two separate 200-megawatt, 800-megawatt-hour battery energy storage systems (“BESS”) with an associated substation located in Olmsted County, Minnesota. Cumulatively the Projects are a 400-megawatt, 1600-megawatt-hour BESS. The major sound sources included in the Projects are the BESS containers equipped with integrated inverters and heating, ventilation, and air conditioning (“HVAC”) equipment, and electrical transformers. The sound study has been completed assuming both Projects operate all of their equipment at full capacity at the same time.

The State of Minnesota has applicable sound level requirements for the Projects. The Projects were analyzed for cumulative sound level impacts at neighboring receptors. The sound level impacts were compared to the industrial nighttime limit of 75 dBA and the residential nighttime limit of 50 dBA, at the nearest respective locations. The battery containers with associated HVAC equipment and transformers were modeled with the provided sound level specifications. The Projects operational sound levels are predicted to be in compliance with the State of Minnesota sound level limits at the neighboring properties.

1.0 Acoustic Terminology

The term “sound level” is often used to describe two different sound characteristics: sound power and sound pressure. Every source that produces sound has a sound power level (“PWL”). The PWL is the acoustical energy emitted by a sound source and is an absolute number that is not affected by the surrounding environment. The acoustic energy produced by a source propagates through media as pressure fluctuations. These pressure fluctuations, also called sound pressure levels (“SPL”), are what human ears hear and microphones measure.

Sound is physically characterized by amplitude and frequency. The amplitude of sound is measured in decibels (“dB”) as the logarithmic ratio of a sound pressure to a reference sound pressure (20 micropascals). The reference sound pressure corresponds to the typical threshold of human hearing. To the average listener, a 3-dB change in a continuous broadband sound is generally considered “just barely perceptible”; a 5-dB change is generally considered “clearly noticeable”; and a 10-dB change is generally considered a doubling (or halving, if the sound is decreasing) of the apparent loudness.

Sound waves can occur at many different wavelengths, also known as the frequency. Frequency is measured in hertz (“Hz”) and is the number of wave cycles per second that occur. The typical human ear can hear frequencies ranging from approximately 20 to 20,000 Hz. Normally, the human ear is most sensitive to sounds in the middle frequencies (1,000 to 8,000 Hz) and is less sensitive to sounds in the lower and higher frequencies. As such, the A-weighting scale was developed to simulate the frequency response of the human ear to sounds at typical environmental levels. The A-weighting scale emphasizes sounds in the middle frequencies and de-emphasizes sounds in the low and high frequencies. Any sound level to which the A-weighting scale has been applied is expressed in A-weighted decibels, or dBA. For reference, the A-weighted sound pressure level and subjective loudness associated with some common sound sources are listed in Table 1-1. The C-weighting scale, expressed as C-weighted decibels or dBC, does not discriminate against low frequencies and measures more uniformly over the frequency range of 30 to 10,000 Hz.

Sound in the environment is constantly fluctuating, as when a car drives by, a dog barks, or a plane passes overhead. Therefore, sound metrics have been developed to quantify fluctuating environmental sound levels. These metrics include the exceedance sound level. The exceedance sound level is the sound level exceeded during “x” percent of the sampling period and is also referred to as a statistical sound level. Common exceedance sound level values are the 10-, 50-, 90-percentile exceedance sound levels, denoted by L_{10} , L_{50} , and L_{90} . The equivalent-continuous sound level (“ L_{eq} ”) is the arithmetic average of the varying sound over a given time period and is the most common metric used to describe sound. Since the L_{eq} is the mean sound level of a given time period and the L_{50} is the median sound level for a given time period, it is common to assume that those two metrics are approximately equal for constant sound sources.

Table 1-1: Typical Sound Pressure Levels Associated with Common Sound Sources

Sound Pressure Level (dBA)	Subjective Evaluation	Environment
140	Deafening	Jet aircraft at 75 feet
130	Threshold of pain	Jet aircraft during takeoff at a distance of 300 feet
120	Threshold of feeling	Elevated train
110	Very loud	Jet flyover at 1,000 feet
100		Motorcycle at 25 feet
90	Moderately loud	Propeller plane flyover at 1,000 feet
80		Diesel truck (40 mph) at 50 feet
70	Loud	B-757 cabin during flight
60	Moderate	Air-conditioner condenser at 15 feet
50	Quiet	Private Office
40		Farm field with light breeze, birdcalls
30	Very quiet	Quiet residential neighborhood
20		Rustling leaves
10	Just audible	--
0	Threshold of hearing	--

Sources:

(1) Adapted from Architectural Acoustics, M. David Egan, 1988

(2) Architectural Graphic Standards, Ramsey and Sleeper, 1994

2.0 Applicable Regulations

2.1 State of Minnesota

The State of Minnesota regulates noise under the Minnesota Administrative Rules Chapter 7030. Chapter 7030 is found within the Minnesota Pollution Control Agency (“MPCA”) 2015 A Guide to Noise Control in Minnesota. Chapter 7030 identifies daytime and nighttime sound level limits based on the NAC of the receiving land use. NAC1 includes noise-sensitive areas such as residential areas, hotels, and medical facilities. NAC2 includes a variety of commercial uses and NAC3 includes manufacturing, industrial, and agricultural uses as further detailed in Section 7030.0050 Subpart 2 of the Minnesota Administrative Rules. Table 2-1 defines the daytime and nighttime sound level limits for all NAC.

Table 2-1: MPCA Sound Level Limitations

Noise Area Classification	Daytime L ₅₀ (dBA)	Daytime L ₁₀ (dBA)	Nighttime L ₅₀ (dBA)	Nighttime L ₁₀ (dBA)
1 (Residential)	60	65	50	55
2 (Commercial)	65	70	65	70
3 (Industrial)	75	80	75	80

2.2 Olmsted County, Minnesota

The Project is located within Olmsted County, Minnesota. There were no identified noise ordinances for Olmsted County applicable to the Project.

2.3 Kalmar Township, Minnesota

The Project is located within Kalmar Township, Minnesota. There were no identified noise ordinances for Kalmar Township applicable to the Project.

3.0 Predictive Modeling

3.1 Methodology

Sound modeling was performed using the industry-accepted sound modeling software Computer Aided Noise Abatement (“CadnaA”), version 2024. The software is a scaled, three-dimensional program, which takes into account air absorption, terrain, ground absorption, and reflections and shielding for each piece of noise-emitting equipment and predicts sound pressure levels. The model calculates sound propagation based on International Organization of Standardization (“ISO”) 9613-2:2024, General Method of Calculation. ISO 9613-2 assesses the sound level propagation based on the octave band center-frequency range from 31.5 to 8,000 Hz.

The ISO standard considers sound propagation and directivity. The software calculates sound propagation using omnidirectional, downwind sound propagation and worst-case directivity factors. In other words, the model assumes that each piece of equipment propagates its maximum sound level in all directions at all times. Empirical studies accepted within the industry have demonstrated that modeling may over-predict sound levels in certain directions, and as a result, modeling results generally are considered a conservative measure of the Project’s actual sound level.

The modeled atmospheric conditions were assumed to be calm, and the temperature and relative humidity were left at the program’s default values. Reflections and shielding were considered for sound waves encountering physical structures. Terrain elevations were included in the model to account for surface effects. Ground absorption values can range from 0.0 (fully reflective surface) to 1.0 (fully absorptive surface). Onsite ground absorption was set to 0.5, as a conservative measure. All sound modeling parameters used are provided in Table 3-1.

Table 3-1: Sound Modeling Parameters

Model Input	Parameter Value
Ground Absorption	0.5
Number of Reflections	2
Receptor Height	5 feet above grade
Temperature	50°F
Humidity	70%

3.2 Project Sound Sources

The main source of operational noise will be the battery containers with integrated inverters and HVAC equipment, and electrical transformers. Project sound sources were modeled according to the locations provided in the general arrangement drawing provided as Figure A-1 of Appendix A. The battery containers were located based on the provided layout. Sound levels for each piece of equipment were provided by the manufacturer or estimated based on similar equipment data, as provided below.

Sungrow provided a noise test report, dated November 2023, for the PowerTitan 2.0 battery system with a maximum measured sound level of 74 dBA at 1 meter on top of the unit where the cooling fans are located. Detailed sound level data was not provided for the substation transformers or MV transformers. The substation transformer was assumed to be 85 dBA at 3 feet and the MV transformers were assumed to be 65 dBA at 3 feet, based on similar equipment. Table 3-2 provides the modeled sound level assumptions

for each piece of modeled equipment. For each piece of modeled equipment, a sound level spectrum was provided by the manufacturer or referenced from equipment of similar size and scope to accurately reflect the frequency characteristics for each source.

Table 3-2: Modeled Source Sound Level Assumptions

Equipment	Number of Sources Modeled	Modeled Sound Pressure Level	Modeled Sound Power Level
PowerTitan 2.0	472	68 dBA at 1 meter	90 dBA
MV Transformer	118	65 dBA at 3 feet	84 dBA
Substation Transformer	2	85 dBA at 3 feet	106 dBA

The battery container HVAC units would not be expected to run simultaneously at full load during nighttime hours due to the lower ambient temperatures at night, but they were modeled with all units at full load as a conservative measure.

3.3 Model Results

The model predicted Project sound levels at the nearest industrial property line (IND01) and at the nearest residential areas. IND01 will be compared to the applicable State of Minnesota nighttime industrial limit of 75 dBA L_{50} . The residential properties will be compared to the applicable State of Minnesota nighttime residential limit of 50 dBA L_{50} . Table 3-3 provides the modeled Project sound levels compared to the State of Minnesota sound limits for the highest model impacts at the industrial and residential properties. The model predicted sound levels assume all equipment is running at full load.

Table 3-3: Modeled Sound Level Results

Receiver	Receiver Type	Modeled Sound Level (dBA)	State of Minnesota Nighttime Limits (L_{50} dBA)
IND01	Industrial	55	75
REC121	Residential	47	50

The industrial receiver was modeled to be below 75 dBA, and all residential receivers were modeled to be at or below 50 dBA with the Project operating at full load, in accordance with the State of Minnesota regulations. Graphical representations of the Project sound levels are provided in Figure A-2 of Appendix A, as 5-dBA sound level contours.

The application guidance for solar farms in Minnesota requires projects to provide a table showing the number of receptors within 3,200 feet of the project and describe how these receptors were identified. This Project is not a solar project but includes similar electrical components. Therefore, receptors within 3,200 feet of the Project have been identified through aerial imagery and are shown on the map in Figure A-2 of Appendix A. The number of receptors within specific distances are provided in Table 3-4. The total number of receptors within 3,200 feet of either Project site is 453. Some receptors are within 3,200 feet of both sites. Tables showing the Project sound level impacts at all receivers within the 3,200-foot boundary are provided in Appendix B.

Table 3-4: Proximity of Residences within 3,200 feet

Distance From Site to Receptor (feet)	Crane Land Control Area	Sandhill Land Control Area
<400	2	2
400-800	1	1
800-1,600	14	102
1,600-3200	226	346


4.0 Conclusion

Burns & McDonnell conducted a sound study for the Projects. The State of Minnesota has applicable sound level requirements for the Projects. The Projects were compared to the industrial nighttime L_{50} sound level limit of 75 dBA at the nearest industrial property and the residential nighttime sound level limit of 50 dBA L_{50} , at the nearest residential locations.

The proposed equipment sound levels were modeled using industry-accepted sound modeling software to predict future sound levels at the property lines and in the surrounding community. Transformers and battery containers are expected to be the significant sound-emitting sources associated with the Projects and were modeled based on conceptual general arrangement drawings. A number of conservative assumptions were applied to the model to predict worst-case sound pressure levels at distance. The model results were then compared to the identified applicable regulations.

The Projects are cumulatively predicted to meet the 50-dBA- L_{50} residential limit at all adjacent residential properties and the 75-dBA- L_{50} industrial limit at all adjacent industrial properties. Although worst-case equipment sound levels were used in the model, daily operating levels may be less.

APPENDIX A – FIGURES



CRANE DESCRIPTION	
NAMEPLATE	200 MW / 800 MWh
CRANE MATERIAL LIST	
NUMBER OF PURPOSE BUILT ENCLOSURES (BOL)	212
NUMBER OF PURPOSE BUILT ENCLOSURES (EOL)	236
NUMBER OF MEDIUM VOLTAGE TRANSFORMERS (BOL)	53
NUMBER OF MEDIUM VOLTAGE TRANSFORMERS (EOL)	59

SANDHILL BESS DESCRIPTION	
NAMEPLATE	200 MW / 800 MWh
SANDHILL MATERIAL LIST	
NUMBER OF PURPOSE BUILT ENCLOSURES (BOL)	212
NUMBER OF PURPOSE BUILT ENCLOSURES (EOL)	236
NUMBER OF MEDIUM VOLTAGE TRANSFORMERS (BOL)	53
NUMBER OF MEDIUM VOLTAGE TRANSFORMERS (EOL)	59


LEGEND:

- PROPERTY LINE
- FENCE
- SETBACK
- GATE
- CRUSHED ROCK LIMITS

ABBREVIATION LIST:

BESS - BATTERY ENERGY STORAGE SYSTEM
BOL - BEGINNING OF LIFE
EOL - END OF LIFE
PCS - POWER CONVERSION SYSTEM
POI - POINT OF INTERCONNECTION
TYP - TYPICAL

- NOTES:**
- FINAL LAYOUT SUBJECT TO CHANGE BASED ON FINAL ENVIRONMENTAL, CIVIL, GEOTECHNICAL, AND AUTHORITY HAVING JURISDICTION REQUIREMENTS.
 - EQUIPMENT QUANTITIES, CONFIGURATION, AND FOOTPRINT SUBJECT TO CHANGE BASED ON FINAL BESS TECHNOLOGY SELECTION AND ADDITIONAL PROJECT DUE DILIGENCE.
 - CIVIL GRADING AND STORMWATER NOT CONSIDERED IN LAYOUT DEVELOPMENT.
 - DESIGN MAINTAINS FACILITY NAMEPLATE RATING THROUGH YEAR 20. AUGMENTATION EVENTS OCCUR AT YEARS 6, 10, 13, AND 17.
 - LANDSCAPING NOT INCLUDED IN LAYOUT DEVELOPMENT.
 - WATER SUPPLY, SUCH AS TANKS, FIRE WATER LOOP, AND/OR HYDRANTS NOT INCLUDED OR CONSIDERED IN LAYOUT DEVELOPMENT.
 - WETLANDS, FLOODPLAINS, AND OTHER ENVIRONMENTAL CONSIDERATIONS SUBJECT TO CHANGE.



PRELIMINARY - NOT FOR CONSTRUCTION

C	10/21/2024	MRA	EDV	ISSUED FOR REVIEW	
B	03/11/2024	MRA	EDV	ISSUED FOR REVIEW	
A	01/18/2024	MRA	JLT	ISSUED FOR REVIEW	
no.	date	by	ckd	description	

no.	date	by	ckd	description	


9400 WARD PARKWAY
KANSAS CITY, MO 64114
816-333-9400
Burns & McDonnell Engineering Co, Inc.

designed
M. ANSTINE

detailed
M. ANSTINE

OLMSTED COUNTY, MINNESOTA

TENASKA CRANE & SANDHILL BATTERY ENERGY STORAGE SYSTEM SITE PLAN	
project	contract
drawing	rev.
LAYOUT — C	
sheet 1 of 1 sheets	
file TenaskaCraneSandhillLayout.dwg	



APPENDIX B – MODELED SOUND LEVELS

APPENDIX B - RECEIVER SOUND LEVELS

Receiver	Sound Level (dBA)	Receiver	Sound Level (dBA)	Receiver	Sound Level (dBA)	Receiver	Sound Level (dBA)	Receiver	Sound Level (dBA)	Receiver	Sound Level (dBA)
IND01	55	REC081	43	REC162	37	REC243	37	REC324	37	REC405	43
REC001	36	REC082	43	REC163	36	REC244	37	REC325	37	REC406	42
REC002	36	REC083	43	REC164	37	REC245	37	REC326	37	REC407	42
REC003	36	REC084	43	REC165	37	REC246	37	REC327	37	REC408	42
REC004	36	REC085	42	REC166	37	REC247	37	REC328	37	REC409	41
REC005	36	REC086	42	REC167	38	REC248	38	REC329	37	REC410	42
REC006	37	REC087	42	REC168	38	REC249	38	REC330	37	REC411	43
REC007	37	REC088	42	REC169	38	REC250	38	REC331	37	REC412	43
REC008	37	REC089	42	REC170	39	REC251	38	REC332	37	REC413	42
REC009	38	REC090	42	REC171	39	REC252	39	REC333	37	REC414	42
REC010	38	REC091	42	REC172	39	REC253	38	REC334	37	REC415	42
REC011	38	REC092	42	REC173	39	REC254	38	REC335	37	REC416	42
REC012	38	REC093	42	REC174	40	REC255	36	REC336	39	REC417	40
REC013	38	REC094	42	REC175	40	REC256	36	REC337	39	REC418	40
REC014	38	REC095	42	REC176	40	REC257	36	REC338	39	REC419	40
REC015	37	REC096	42	REC177	41	REC258	37	REC339	39	REC420	40
REC016	37	REC097	43	REC178	41	REC259	37	REC340	39	REC421	40
REC017	38	REC098	43	REC179	37	REC260	37	REC341	39	REC422	40
REC018	37	REC099	43	REC180	37	REC261	37	REC342	40	REC423	41
REC019	37	REC100	44	REC181	37	REC262	36	REC343	40	REC424	41
REC020	37	REC101	43	REC182	37	REC263	36	REC344	40	REC425	41
REC021	36	REC102	43	REC183	38	REC264	36	REC345	40	REC426	41
REC022	37	REC103	43	REC184	38	REC265	36	REC346	40	REC427	41
REC023	37	REC104	43	REC185	39	REC266	36	REC347	40	REC428	41
REC024	36	REC105	43	REC186	39	REC267	36	REC348	41	REC429	41
REC025	36	REC106	43	REC187	39	REC268	36	REC349	41	REC430	41
REC026	36	REC107	44	REC188	39	REC269	37	REC350	41	REC431	40
REC027	36	REC108	44	REC189	40	REC270	37	REC351	41	REC432	40
REC028	36	REC109	44	REC190	40	REC271	38	REC352	42	REC433	40
REC029	36	REC110	45	REC191	41	REC272	38	REC353	42	REC434	39
REC030	36	REC111	45	REC192	41	REC273	38	REC354	41	REC435	39
REC031	36	REC112	45	REC193	41	REC274	38	REC355	41	REC436	39
REC032	36	REC113	44	REC194	42	REC275	38	REC356	41	REC437	39
REC033	36	REC114	44	REC195	42	REC276	38	REC357	41	REC438	39
REC034	37	REC115	44	REC196	42	REC277	38	REC358	41	REC439	39
REC035	37	REC116	44	REC197	41	REC278	38	REC359	40	REC440	39
REC036	37	REC117	44	REC198	41	REC279	38	REC360	41	REC441	39
REC037	37	REC118	44	REC199	41	REC280	37	REC361	41	REC442	39
REC038	37	REC119	44	REC200	41	REC281	37	REC362	41	REC443	39
REC039	38	REC120	45	REC201	41	REC282	37	REC363	41	REC444	39
REC040	38	REC121	47	REC202	40	REC283	37	REC364	40	REC445	38
REC041	38	REC122	46	REC203	40	REC284	37	REC365	40	REC446	38
REC042	39	REC123	45	REC204	40	REC285	36	REC366	40	REC447	38
REC043	39	REC124	45	REC205	40	REC286	36	REC367	40	REC448	39
REC044	39	REC125	45	REC206	40	REC287	36	REC368	40	REC449	39
REC045	39	REC126	44	REC207	40	REC288	36	REC369	40	REC450	39
REC046	40	REC127	44	REC208	39	REC289	36	REC370	39	REC451	37
REC047	40	REC128	44	REC209	39	REC290	36	REC371	39	REC452	39
REC048	40	REC129	43	REC210	39	REC291	37	REC372	39		
REC049	40	REC130	43	REC211	39	REC292	37	REC373	39		
REC050	40	REC131	43	REC212	39	REC293	37	REC374	39		
REC051	41	REC132	42	REC213	39	REC294	37	REC375	39		
REC052	41	REC133	42	REC214	39	REC295	38	REC376	40		
REC053	41	REC134	42	REC215	38	REC296	38	REC377	40		
REC054	41	REC135	41	REC216	38	REC297	39	REC378	40		
REC055	41	REC136	41	REC217	38	REC298	42	REC379	40		
REC056	42	REC137	41	REC218	38	REC299	43	REC380	40		
REC057	41	REC138	40	REC219	38	REC300	44	REC381	40		
REC058	41	REC139	40	REC220	38	REC301	41	REC382	40		
REC059	42	REC140	40	REC221	37	REC302	44	REC383	40		
REC060	42	REC141	40	REC222	37	REC303	42	REC384	39		
REC061	42	REC142	39	REC223	37	REC304	41	REC385	39		
REC062	42	REC143	39	REC224	37	REC305	46	REC386	39		
REC063	42	REC144	39	REC225	37	REC306	46	REC387	39		
REC064	43	REC145	39	REC226	36	REC307	40	REC388	39		
REC065	43	REC146	39	REC227	37	REC308	38	REC389	39		
REC066	43	REC147	38	REC228	37	REC309	38	REC390	38		
REC067	43	REC148	38	REC229	37	REC310	38	REC391	41		
REC068	43	REC149	38	REC230	37	REC311	38	REC392	41		
REC069	43	REC150	37	REC231	37	REC312	38	REC393	41		
REC070	43	REC151	37	REC232	37	REC313	38	REC394	41		
REC071	44	REC152	37	REC233	36	REC314	38	REC395	41		
REC072	43	REC153	37	REC234	37	REC315	38	REC396	42		
REC073	43	REC154	37	REC235	37	REC316	37	REC397	42		
REC074	43	REC155	37	REC236	37	REC317	37	REC398	42		
REC075	44	REC156	37	REC237	36	REC318	37	REC399	42		
REC076	44	REC157	37	REC238	36	REC319	37	REC400	43		
REC077	44	REC158	37	REC239	36	REC320	37	REC401	43		
REC078	44	REC159	37	REC240	36	REC321	37	REC402	43		
REC079	44	REC160	37	REC241	36	REC322	37	REC403	43		
REC080	44	REC161	37	REC242	37	REC323	37	REC404	43		

